



ENVIRONMENTAL CLAIM VALIDATION SUMMARY

Plasma Air International

Plasma Air, Models PA601, PA602, PA603, PA604

Report Number:

168693-4180

Validation Period:

10/08/2020 - 10/08/2021

Project Number:

4789366929

Claim:

Zero Ozone Emissions – Measured Ozone Emissions from Air Ionizer PA600 Series during use phase does not exceed 0.005 ppm as tested by UL 867.

Method:

ECVP 2998 Zero Ozone Emissions from Air Cleaners, Third Edition - 2020

Facility:

Stratford