



01st June 2021

To Whom It May Concern,

Plasma Air Ionisation Product PA604 has a DC voltage of less than 5kV between the two brushes as measured with the following instruments:

- Testec HPV-40 1000:1 Probe
- Fluke 115 True RMS multimeter

Christopher Russell



VP Plasma Air International

*Chris Russell*